

ADDENDUM NO. 4

VILLAGE OF OHIO CITY Storm Drainage Improvements September 9, 2016

To: Planholders

From: Mote & Associates, Inc.
214 West Fourth Street
Greenville, Ohio 45331

Phone: (937) 548-7511
Fax: (937) 548-7484
E-mail: info@moteassociates.com

Re: Village of Ohio City
Storm Drainage Improvements

This Addendum forms a part of the Contract Documents and modifies the original Contract Documents dated August 2016 along with Addendum #1 of September 1, 2016, Addendum #2 of September 2, 2016, and Addendum #3 of September 7, 2016. Acknowledge receipt of all Addendums in the space provided on the Revised Bid Proposal Form #2. Failure to do so may subject the Bidder to disqualification.

GENERAL CLARIFICATIONS:

1. Catch Basins in non-paved areas shall utilize the following grates and frames:

- a) East Jordan 5110 Type M3 or
- b) Neenah R-4859-C

2. Catch Basins in paved areas shall utilize the following grates and frames:

- a) East Jordan 5250 Type M3 or
- b) Neenah R-3405
- c) The following locations of proposed catch basins are in paved areas:
 - Sheet 7/23 – Structures 5 and 6 (Type 2-3 Catch Basins)
 - Sheet 8/23 – Structure 11 (Type 2-3 Catch Basin)
 - Sheet 9/23 – Structures 9 and 10 (Type 2-5 Catch Basin)
 - Sheet 10/23 – Structure 11 (Type 2-4 Catch Basin)
 - Sheet 19/23 – Structure 8 (Type 2-3 Catch Basin)
 - Sheet 20/23 – Structure 8 (Type 2-4 Catch Basin)
 - Alternate Bid #1 – Williams/Jefferson St. – 1 – 2-4 Catch Basin
 - Alternate Bid #1 – Jefferson/Shanes St. – 2 – 2-4 Catch Basins
 - Alternate Bid #1 – Banner/Shanes St. – 2 – 2-4 Catch Basins
 - Alternate Bid #1 – Hoffman/Shanes St. – 1 – 2-3 Catch Basin
 - Alternate Bid #1 – Skinner/Shanes St. – 1 – 2-3 Catch Basin
 - All other structures shall utilize the grate/frame specified for non-paved areas.

- d) The cost of the grate/frame shall be included with the unit cost of the respective catch basin line item. The type of grate used for each structure shall be as specified herein. No separate listing has been made for the different grate types. It is the contractor's responsibility to adjust the unit price bid accordingly for each catch basin type to cover all labor, equipment, and material costs to provide a complete installation.

CHANGES/CLARIFICATIONS TO THE DETAIL CONSTRUCTION PLANS

3. Revised Sheets #9/23 and #10/23 (from Addendum #1) specify 52"-54" storm conduit extended from existing 54" storm conduit south of the Carmean/Ball Road intersection. If 54" conduit is no longer available, please furnish 60" conduit along with a 60" x 54" eccentric reducer. The cost of this installation shall be listed on the unit price bid for 54" conduit Type B on the bid form.

End of Addendum