

ADDENDUM NO. 1

VILLAGE OF UNION CITY Sanitary Sewer Rehabilitation Phase III March 7, 2014

To: Planholders

From: Mote & Associates, Inc.
214 West Fourth Street
Greenville, Ohio 45331
Phone: (937) 548-7511
Fax: (937) 548-7484
E-mail: info@moteassociates.com

Re: Village of Union City
Sanitary Sewer Rehabilitation Phase III

This Addendum forms a part of the Contract Documents and modifies the original Contract Documents dated February, 2014. Acknowledge receipt of this Addendum in the space provided on the Bid Proposal form. Failure to do so may subject the Bidder to disqualification.

CHANGES/CLARIFICATIONS TO THE BIDDING REQUIREMENTS:

1. Section 00 41 43, BID FORM & Section 00 52 43, AGREEMENT FORM

The project completion date in both of these documents shall be extended thirty (30) calendar days; and therefore, changed from June 30, 2014 to July 30, 2014.

CHANGES/CLARIFICATIONS TO THE TECHNICAL SPECIFICATIONS:

2. Section 33 01 30.72, CURED-IN-PLACE PIPE (CIPP)
 - A, Section 3.02, Installation, Item 5 shall be revised to include installation with steam pressure to correspond with Section 1.01 which allows the use of steam pressure:

Section 3.02, Item 5 shall be revised to state: "Curing shall be accomplished by utilizing hot water under hydrostatic pressure or steam pressure in accordance with the manufacturer's recommended cure schedule."
 - B. The Contractor will be allowed to utilize the Owner's fire hydrants as their water source, if needed. The water will be metered by the Owner. The Contractor will be charged \$2.84 per 100 cubic feet of water used in the completion of the work.
 - C. Section 3.01, Installation Responsibilities for Incidental Items, Item B states: "...The Owner shall provide a local dump site for all debris removed from the sewers during the cleaning operation...." Please note that the Owner does NOT have a place to dispose of the debris and it will be the Contractor's responsibility to find a dump site.

3. Section 33 01 30.62, SEWER MANHOLE REHABILITATION

A. Section 3.01, General, Item C. states the following:

“All steps that are in poor condition and that are directed by the engineer shall be removed completely from those manholes receiving cementitious lining. New steps shall be installed once the cementitious lining process is complete. All steps that are in good condition shall remain and shall be protected during the lining process....”

Please note that all manhole step replacement will be based on the decision of the Engineer. The cost for manhole step replacement will be based on the unit price bid in Alternate #2.

End of Addendum