## ADDENDUM NO. 1

## BOARD OF DARKE COUNTY COMMISSIONERS 911 Center Relocation @ Darke Co. Sheriff's Office July 26, 2018

To: Planholders From: Mote & Associates, Inc. 214 West Fourth Street Greenville, Ohio 45331

 Phone:
 (937) 548-7511

 Fax:
 (937) 548-7484

 E-mail:
 info@moteassociates.com

Re: Board of Darke County Commissioners 911 Center Relocation @ Darke Co. Sheriff's Office

This Addendum forms a part of the Contract Documents and modifies the original Contract Documents dated July 2018. Acknowledge receipt of this Addendum in the space provided on the Bid Proposal form. Failure to do so may subject the Bidder to disqualification.

THE FOLLOWING ARE REVISIONS AND CLARIFICATIONS TO THIS PROJECT:

- 1. On Drawing E2-03, change Keynote 1 to read: "Relocate existing low voltage push button and buzzer system, including any power supply. Provide low voltage wiring to match existing wiring and extend the power circuit to the new location. This requirement supersedes Keynote 13 for this item on Drawing E1-01.
- 2. On Drawing E1-01, add the following General Note: At the removed wall between Rooms 020 and 021, re-support all items to remain that are supported from or on the wall that is to be removed. All re-supported item locations shall be as directed by the Owner, within 10 feet of the existing location. Extend all services to relocated items except that all data system wiring and data system components that must be relocated will be relocated and re-supported by the Owner's vendor.
- 3. On Drawing E1-01, in Keynote 16, change "Vibrant" to "Vigilant".
- 4. The General Contractor shall be responsible for coordinating work with Owner's outside vendors which work is to be performed under separate contracts for cabling (P& R Communications), telephone system (Doss Business Systems), and the computer console system (Provider to be determined). All costs for the General Contractor to coordinate efforts shall be included in the General Contractor's bid.
- 5. There is very limited space for storage of Contractor's materials within the 911/Communications Facility. The General Contractor shall include all costs for providing temporary storage units to accommodate all material storage needs.
- 6. The General Contractor shall include in his/her bid costs for removal and disposal of old 911 console furniture once they have been taken out of service. The Owner does reserve the right to retain old units should they desire to do so.
- 7. Bid due date remains 1:00 P.M., Wednesday, August 1, 2018 to be received by Board of Darke Co. Commissioners at County Administration Bldg., 520 S. Broadway, Greenville, Ohio 45331.

End of Addendum