

## **ADDENDUM NO. 2**

### Board of Darke County Commissioners Courthouse Security Entrance Addition

May 23, 2019

To: Planholders

From: Mote & Associates, Inc.  
214 West Fourth Street  
Greenville, Ohio 45331

Phone: (937) 548-7511  
Fax: (937) 548-7484  
E-mail: info@moteassociates.com

Re: Board of Darke County Commissioners  
Courthouse Security Entrance Addition

This Addendum forms a part of the Contract Documents and modifies the original Contract Documents dated May 1, 2019 and Addendum No. 1 dated May 21, 2019. Acknowledge receipt of this Addendum in the space provided on the Bid Proposal Form. Failure to do so may subject the Bidder to disqualification.

#### CHANGES/CLARIFICATIONS TO THE CONSTRUCTION DRAWINGS:

##### 1. SHEET S0-01, STRUCTURAL NOTES, SCHEDULES, AND DETAILS

- a. In the Structural Design Table Item 3, after the words, "SNOW DRIFT" and after "MAXIMUM DRIFT INTENSITY", add the words "FOR DRIFT FROM THE EXISTING BUILDING ONTO BOTH THE ADDITION HIGH ROOF AND VESTIBULE ROOF".
- b. In the Structural Design Table Item 3, add the following, "For snow drift from the Addition High Roof onto the Addition Vestibule Roof, the cold-formed steel trusses shall be designed to withstand a Maximum Drift Intensity of 54 PSF and a Drift Width of 10 feet.

##### 2. SHEET S1-01, FOUNDATION AND STRUCTURAL PLAN

- a. On the Structural Plan, change the roof beam adjacent to the existing building from "W12x27" to "W12x26".

##### 3. SHEET G3-03, ROOF EDGE DETAILS

- a. On the Roof Edge at Existing Wall Detail, change the 2 inch dimension to 1 inch and note that the existing building line exists at this location, although it does not show on the detail.

End of Addendum