

ADDENDUM NO. 3

VILLAGE OF BOTKINS Wastewater Treatment Plant UV Disinfection Upgrades August 27, 2019

To: Planholders

From: Mote & Associates, Inc. Phone: (937) 548-7511
214 West Fourth Street Fax: (937) 548-7484
Greenville, Ohio 45331 E-mail: info@moteassociates.com

Re: Village of Botkins
Wastewater Treatment Plant UV Disinfection Upgrades

This Addendum forms a part of the Contract Documents and modifies the original Contract Documents dated August 2019, and Addendum #1 dated August 21, 2019, and Addendum #2 dated August 26, 2019. Acknowledge receipt of this Addendum in the space provided on the Bid Proposal form. Failure to do so may subject the Bidder to disqualification.

CHANGES/CLARIFICATIONS TO THE BIDDING DOCUMENTS:

1. ADVERTISEMENT FOR BIDS, SECTION 00 11 13

The time for the opening of the Bids has been extended to Wednesday, September 4, 2019 at 1:00 PM (local time). The bid opening will take place at the Village of Botkins Office, 200 South Mill Street, Botkins, Ohio.

GENERAL CLARIFICATIONS

2. Project elevation:
 - a. There is a source of fill material on-site from a previous project that can be utilized to obtain the appropriate project elevation as shown on the Drawings. See attached drawing for material location.
 - b. The Engineer's estimate for required back-fill material is ± 300 cubic yards.
 - c. The fill material supply area must be re-seeded after completion of the project.
3. The Contractor can submit their concrete pour layout prior to construction if it deviates from the drawings for approval. Vertical joint between the intermediate floors and the walls are acceptable using DBR connectors. The base slab and wall joints must be placed as drawn.
4. The Engineer's Estimate has been increased to \$360,000.00

End of Addendum

Attachments: Spoils Area Drawing



Sidney Wapakoneta Rd

THIS IS A SPOILS
AREA FROM A
PREVIOUS PROJECT

