

ADDENDUM NO. 1

VILLAGE OF COVINGTON WATER TREATMENT PLANT FILTER MEDIA REPLACEMENT April 6, 2020

To: Planholders

From: Mote & Associates, Inc.
214 West Fourth Street
Greenville, Ohio 45331

Phone: (937) 548-7511
Fax: (937) 548-7484
E-mail: info@moteassociates.com

Re: Village of Covington
Water Treatment Plant Filter Media Replacement

This Addendum forms a part of the Contract Documents and modifies the original Contract Documents dated March 2020. Acknowledge receipt of this Addendum in the space provided on the Bid Proposal Form. Failure to do so may subject the Bidder to disqualification.

GENERAL CLARIFICATIONS:

1. The media shall be supplied by any supplier or manufacturer, providing it meets aggregate media gradation specifications and is NSF61 approved.
2. This project is classified as "maintenance" to the water treatment plant; and therefore, is not subject to the State's prevailing wage law. No prevailing wages shall be required in the completion of this work.

End of Addendum