

ADDENDUM NO. 1

VILLAGE OF LAURA MIAMI COUNTY, OHIO STANDBY GENERATOR October 22, 2024

To: Planholders


From: Mote & Associates, Inc.
214 West Fourth Street
Greenville, Ohio 45331
Phone: (937) 548-7511
Fax: (937) 548-7484

Re: Village of Laura
Standby Generator



This addendum forms a part of the Contract Documents and modifies the original Contract Documents dated October 2024. Acknowledge receipt of this Addendum in the space provided on the Bid Proposal form. Failure to do so may subject the Bidder to disqualification.

CLARIFICATIONS / REVISIONS/ADDITIONS TO PLAN SHEETS:

1. The electric supply conductor that runs from the water treatment building to the overhead light mounted at the fence line may be required to be temporarily removed to allow excavation, foundation, and equipment placement work.



2. Should the targeted completion date of April 1, 2025, not be attainable due to product lead times, please note your required time extension in your bid. This time will be used to make adjustments for the target completion date once the project has been awarded.
3. The generator placement will require 12 bollards to be placed 18" on the outside of the fence as seen in the sketch below. The bollards shall be 4" diameter schedule 40 steel pipe per the typical bollard detail below.



End of Addendum