

ADDENDUM NO. 2

VILLAGE OF LAURA
MIAMI COUNTY, OHIO
STANDBY GENERATOR
November 1, 2024

To: Planholders

From: Mote & Associates, Inc.
214 West Fourth Street
Greenville, Ohio 45331
Phone: (937) 548-7511
Fax: (937) 548-7484

Re: Village of Laura
Standby Generator

This addendum forms a part of the Contract Documents and modifies the original Contract Documents dated October 2024. Acknowledge receipt of this Addendum in the space provided on the Bid Proposal form. Failure to do so may subject the Bidder to disqualification.

CLARIFICATIONS / REVISIONS/ADDITIONS TO PLAN SHEETS:

1. On the drawing bid set documents, sheet E6-01, Power Plan Keynote 12, showed the fuel tank size as “300 gallon”, this should have been “a minimum of 300 gallon”. The tank capacity is dictated by the specifications which require a minimum operation of 72 hours at 50% load, and 48 hours at 100% load.

End of Addendum